

3M Deutschland GmbH

Carl-Schurz-Straße 1
41453 Neuss

+49 (0)2131/140
+49 (0)2131/142649
Internet: www.3M.de
E-Mail: innovation.de@3M.com
WEEE-Reg.-Nr. DE 36963167
VAT-ID: DE 120679179



26 August 2024

Flammability of 3M Products

Classification of fire behavior

Product	3M™ Scotchshield™ Window Film Security System S2400
	laminated with: -
Substrate	Glass panel, thickness 4 mm
Commissioned Testing Institute	Materialprüfungsamt NRW - Brandprüfzentrum Erwitte Auf den Thränen 2 59597 Erwitte
Classified according to Standard	DIN EN 13501-1:2019-05

Fire classification of construction and building elements.

Test report of the reaction to fire performance no.: 231002144-3, 8/15/2024

Classification using data from reaction to fire tests:

Testing according to DIN EN 13823: Classification report no.: 231002144-1, 8/15/2024

Testing according to DIN EN 13823: Classification report no.: 231002144-2, 8/15/2024

The validity of the classification report no. 231002144-3 is not limited

With reference to the present test reports, the company 3M Deutschland GmbH confirms the following resulting overall classification.

B-s1, d0

The product 3M™ Scotchshield™ Window Film Security System S2400 laminated with - on Glass thus fulfills the requirement sets according to DIN EN 13501-1:2019-05.

3M Deutschland GmbH

DocuSigned by:

ppa: Felix von Zeppelin
Area Director
Commercial Branding & Transportation Division
Europe, Middle East & Africa

Signed by:

i. v. Clarissa Schoenitz
Senior Technical Manager
Commercial Branding & Transportation Division
Europe, Middle East & Africa
Technical Key Account Manager focus Rail