

3M Deutschland GmbH

Carl-Schurz-Straße 1
41453 Neuss

+49 (0)2131/140
+49 (0)2131/142649
Internet: www.3M.de
E-Mail: innovation.de@3M.com
WEEE-Reg.-Nr. DE 36963167
VAT-ID: DE 120679179



12 June 2025

Test of Resistance against Manual Attack according to DIN EN 356

Classification of resistance

1.1 Product

Material: **3M™ Scotchshield™ Window Film Security System S2400**
Substrate: Glass 4 mm

1.2 Commissioned Testing Institute

TÜV Rheinland Nederland B.V., Westervoortsedijk 73, NL-6827 AV Arnhem Classified
according to Standard: **DIN EN 356:1999 (E)**
Glass in Building, Impact Test Method and Classification for Flat Glass
Report no. 89225414-01 25 April 2025.
The validity of the classification report no. 89225414-01 is not limited.

1.3 With reference to the standard and the present test reports, the company 3M Deutschland GmbH confirms the following resulting overall classification.

P3A (impacted on glass side of tested panel)

The product 3M™ Scotchshield™ Window Film Security System S2400, laminated on 4 mm glass, thus fulfills the requirement set according to the test report result P3A for the glass impact side.

3M Deutschland GmbH

DocuSigned by:

C7E1313B03554DD...

ppa. Felix von Zeppelin
Area Director
Commercial Branding & Transportation Division
Europe, Middle East & Africa

Signed by:

AFAA10D23A614F0...

i. V. Clarissa Schoenitz
Senior Technical Manager
Commercial Branding & Transportation Division
Europe, Middle East & Africa
Technical Key Account Manager focus Rail

This confirmation refers exclusively to the named product combination. The basis are the mentioned test reports of the commissioned test institutes for the classification of the fire behavior. The validity ends when the product or the referring standard is changed.